



Rajasthan State Mines & Minerals Limited

(A Government of Rajasthan Enterprise)

Registered Office
C89-90, Lal Kothi Scheme, Janpath
Jaipur (Rajasthan)India
Ph.:+91-1410-2743734. 2743934
Fax: +91-141-2743735
CIN No.: U14109RJ1949SGC000505

Corporate Office
4, Meera Marg,
Udaipur – 313 001
Ph.: -91-294 2428768, 2428763-67

e-mail naveengupta.rsmml@rajasthan.gov.in
website: www.rsmm.com

Ref: RSMM/CO/MM/2024-25

Dated: 11.02.2025

CORRIGENDUM No. 4

Sub- e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25 Dated 8.01.2025 for Site study, design, manufacture, supply, installation, testing and commissioning of 12 nos. 3 pole, 11KV, 50HZ VCB panels indoor type including voltage transformers, current transformers, metering instruments, indications, protection relays etc as per the technical specifications after dismantling the old HT panel from 33KV Sub-station at Jhamarkotra mines, Udaipur.

Following amendment is made to above mentioned tender-

Clause no./Ref. no.	Amendment
Point / Clause no. 22 of (B), General Requirement of Annexure-VI and wherever applicable in tender document	<p><u>Said point/ clause may be read as under-</u></p> <p>22. <u>Testing and Certification Requirement for VCB Panels</u></p> <p>A. All routine tests for the cubicle shall be conducted by the supplier in accordance with the latest applicable Indian Standards. The test report shall be provide to RSMML.</p> <p>B. The bidder shall submit type test reports for VCB panels along with the offer, including the following tests:-</p> <ul style="list-style-type: none">• Temperature Rise Test• Short Circuit Impulse Test• IP 4X Test• Internal Arc Test(26.3 KA for 1 sec)

	<p>C. If the bidder does not possess type test certificate for the internal arc test (26.3 KA for 1 sec), the following alternative is permissible:</p> <p>(i) The bidder may procure the VCB and its complete enclosure from the OEM of the VCB and furnish the type test certificate for the internal arc (26.3 KA for 1 sec) issued by the OEM.</p> <p>(ii) The bidder shall also submit undertaking at the time of tender participation, mentioning the name of the VCB OEM.</p> <p>(iii) Additionally, certified drawing of the enclosure supplied by the VCB OEM shall be submitted for approval after the issuance of the purchase order by RSMML.</p>
--	---

Note:

- i) All other terms & conditions of tender & subsequent amendment will remain unchanged.
- ii) Bidders are requested to furnish their offer in accordance to the details, as above. Further, Bidders are requested to enclose sealed & signed copy of this corrigendum alongwith part-I of their offer towards acceptance of amendment / clarifications made, as above.

For more details, tenderer may contact Ex. Dy. Gen. Manager (MM) at the above address.

(Dr. S S Daiya)
Head (MM)